

Fire Protection – Construction

- | Yes | No | N/A | |
|-----------------------|-----------------------|-----------------------|---|
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 1. Do you have a fire protection program for all phases of construction or demolition work?
29 CFR 1926.150(a)(1) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 2. Is access to all available fire fighting equipment maintained at all times?
29 CFR 1926.150(a)(2) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 3. Is fire fighting equipment you provide conspicuously located?
29 CFR 1926.150(a)(3) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 4. Is fire fighting equipment periodically inspected and if defective immediately replaced?
29 CFR 1926.150(a)(4) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 5. Is a fire extinguisher, rated not less than 2A, provided for each 3,000 square feet of the protected building area, or major fraction thereof?
29 CFR 1926.150(c)(1)(i) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 6. Does travel distance from any point of the protected area to the nearest fire extinguisher not exceed 100 feet?
29 CFR 1926.150(c)(1)(i) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 7. Is there at least one fire extinguisher, rated not less than 2A, provided on each floor?
29 CFR 1926.150(c)(1)(iv) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 8. Is there at least one fire extinguisher located adjacent to stairways on each floor of a multistory building?
29 CFR 1926.150(c)(1)(iv) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 9. Is a fire extinguisher, rated not less than 10B, provided within 50 feet of wherever more than 5 gallons of flammable or combustible liquids or 5 pounds of flammable gas is being used on the jobsite?
29 CFR 1926.150(c)(1)(vi) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 10. Do you prohibit the use of carbon tetrachloride or other toxic vaporizing liquid fire extinguishers?
29 CFR 1926.150(c)(1)(vii) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 11. Are portable fire extinguishers inspected periodically and maintained in accordance with maintenance and use of portable fire extinguishers, NFPA. No. 10A–1970?
29 CFR 1926.150(c)(1)(viii) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 12. Do you have an alarm system whereby the local fire department can be alerted for emergencies?
29 CFR 1926.150(e)(1) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 13. Do you have an alarm system whereby employees on the site can be alerted for emergencies?
29 CFR 1926.150(e)(1) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 14. Is the alarm code or reporting instructions conspicuously posted at phones or at employee entrances?
29 CFR 1926.150(e)(2) |

Fire Prevention—Construction

- | Yes | No | N/A | |
|-----------------------|-----------------------|-----------------------|--|
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 15. Is smoking prohibited at or in the vicinity of operations which constitute a fire hazard, and is “No Smoking or Open Flame” conspicuously posted?
29 CFR 1926.151(a)(3) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 16. Is portable fire extinguishing equipment, suitable for the fire hazards involved, provided at convenient conspicuously accessible locations in the yard area? |

Fire Protection – Construction

- [29 CFR 1926.151\(c\)\(6\)](#)
17. Are portable fire extinguishers, rated not less than 2A, placed so that maximum travel distance to the nearest unit does not exceed 100 feet?
- [29 CFR 1926.151\(c\)\(6\)](#)
18. Do you make certain that indoor storage does not obstruct or adversely affect the means of exit?
- [29 CFR 1926.151\(d\)\(1\)](#)

Fire Protection: Flammable and Combustible Liquids—Construction

- | Yes | No | N/A | |
|-----------------------|-----------------------|-----------------------|--|
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 19. Do you use approved containers and portable tanks for the storage and handling of flammable and combustible liquids?
29 CFR 1926.152(a)(1) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 20. Do you make certain flammable or combustible liquids are not stored in areas normally used for the safe passage of people?
29 CFR 1926.152(a)(2) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 21. Are portable outdoor storage tanks for flammable or combustible liquids at least 20 feet from buildings?
29 CFR 1926.152(c)(4)(i) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 22. Are outdoor storage areas for flammable or combustible liquids kept free of combustible materials not necessary to the storage?
29 CFR 1926.152(c)(5) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 23. Is a portable fire extinguisher having a rating of not less than 20-B units located between 25 feet and 75 feet from flammable liquid storage areas located outside?
29 CFR 1926.152(d)(2) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 24. Is at least one portable fire extinguisher having a rating of not less than 20-B:C units provided on all vehicles used for transporting and/or dispensing flammable or combustible liquids?
29 CFR 1926.152(d)(4) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 25. Is the transfer of flammable liquids from one container to another done only when the containers are electrically interconnected (bonded)?
29 CFR 1926.152(e)(2) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 26. Are flammable liquids kept in closed containers when not actually in use?
29 CFR 1926.152(f)(1) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 27. Are conspicuous and legible signs prohibiting smoking posted in service and refueling areas?
29 CFR 1926.152(g)(9) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 28. Is each service or refueling area provided with at least one fire extinguisher having a rating of not less than 20-B:C?
29 CFR 1926.152(g)(11) |
| <input type="radio"/> | <input type="radio"/> | <input type="radio"/> | 29. Is a fire extinguisher located within 75 feet of each pump, dispenser, underground fill pipe opening, or lubrication or service area?
29 CFR 1926.152(g)(11) |

Notes: